


(12) UK Patent Application (19) GB (11) 2 007 926 A

(21) Application No 7836986
(22) Date of filing 15 Sep 1978
(23) Claims filed 15 Sep 1978
(30) Priority data
(31) 846043
(32) 27 Oct 1977
(33) United States of America (US)
(43) Application published 23 May 1979
(51) INT CL^a H02J 4/00
(52) Domestic classification H2H AK
(56) Documents cited None
(58) Field of search G3N H2H
(71) Applicants Westinghouse Electric Corporation, Westinghouse Building, Gateway Center, Pittsburgh, Pennsylvania, United States of America
(72) Inventors Robert Alfred Yannone John Francis Reuther
(74) Agents Ronald Van Berlyn

(54) Control systems for multiple gas turbine-generator units

(57) A control system for multiple gas turbine-generator units 12 comprises a local control computer 14 which computes a maximum permissible output for each gas turbine-generator unit independently as a dynamic function of combustor shell pressure and exhaust temperature in that unit and the output thus obtained is transmitted to a central control 16. Load demands calculated for each unit are dispatched from the central control to individual local control arrangements 18 which respond to control their respective gas turbine-generators in a manner not to exceed the respective maximum output. Each turbine control 14 sets its generator output at a preset level which is modified by load change signals from the central control 16 and each control 14 operates its turbine fuel control to satisfy the load demand.

ERRATUM
SPECIFICATION NO 2007926A
Foot of front page, insert Certain of the mathematical formula(e) appearing in the printed specification were submitted in formal form after the date of filing.
Bas 71918/16
THE PATENT OFFICE
23 October 1979



SEE ERRATA SELF ATTACHED


GB 2 007 926 A

(12) UK Patent Application (19) GB (11) 2 007 926 A



(21) Application No 7836886
 (22) Date of filing 15 Sep 1978
 (23) Claims filed 15 Sep 1978
 (30) Priority data
 (31) 848043
 (32) 27 Oct 1977
 (33) United States of America (US)
 (43) Application published 23 May 1979
 (51) INT CL²
 H02J 4/00
 (52) Domestic classification
 H2H AK
 (56) Documents cited
 None
 (58) Field of search
 G3N
 H2H
 (71) Applicants
 Westinghouse Electric Corporation,
 Westinghouse Building,
 Gateway Center,
 Pittsburgh, Pennsylvania,
 United States of America
 (72) Inventors
 Robert Alfred Yannoni
 John Francis Reuther
 (74) Agents
 Ronald Van Berlyn

(54) Control systems for multiple gas turbine-generator units

(57) A control system for multiple gas turbine-generator units 12 comprises a local control computer 14 which computes a maximum permissible output for each gas turbine-generator unit independently as a dynamic function of combustor shell pressure and exhaust temperature in that unit and the output thus obtained is transmitted to a central control 16. Load demands calculated for each unit are dispatched from the central control to individual local control arrangements 18 which respond to control their respective gas turbine-generators in a manner not to exceed the respective maximum output. Each turbine control 14 sets its generator output at a preset level which is modified by load change signals from the central control 16 and each control 14 operates its turbine fuel control to satisfy the load demand.



GB 2 007 926 A






FIG. 2.




FIG. 6.

2607926

3/4




FIG. 3.




FIG. 4.




FIG. 5.




FIG. 8.

SPECIFICATION

System for providing load-frequency control for multiple gas turbine-generator units

5

This invention relates to load-frequency control (LFC) and more particularly to systems arranged to execute LFC actions through gas turbine-generator units.

10

Load-frequency control is needed in power systems to hold frequency substantially constant as load changes occur. LFC is typically performed by a dispatch computer and the load changes needed to control the system frequency are dispatched to the various plant locations for implementation by local plant controls.

15

Gas turbine-generator units have been used to execute LFC commands to obtain better system response to load demands and more efficient use of prime movers when used with or without steam turbine-generator units. For example, in the Jersey Central Power & Light system, LFC has been implemented through gas turbine-generator units. However, that implementation has been limited in efficiency because of the manner in which allowable turbine load limits are calculated and implemented.

25

It is an object of this invention to provide an improved load-frequency control system for multiple gas turbine-generator units with a view to overcoming the deficiencies of the prior art.

30

The invention resides in a load-frequency control system for a power system having a plurality of gas turbine-generator units, said control system comprising means for controlling the load level of each of said gas turbine-generator units to satisfy a load reference applied thereto, means for generating the load references for the respective units to provide for substantially constant system frequency substantially without exceeding a high blocking limit for each of said units, means provided for generating representation of turbine exhaust temperature and combustor shell pressure for each unit, and means for dynamically generating the high blocking limit for each of said units as a function of the turbine exhaust temperature and the combustor shell pressure.

45

The invention will become readily apparent from the following description of an exemplary embodiment thereof when read in conjunction with the accompanying drawings, in which:

50

Figure 1 shows a schematic diagram of a power system showing multiple gas turbines for use in LFC;

Figure 2 shows a more detailed schematic of a local control arrangement responsive to control supervisory signals;

55

Figures 3-5 show block diagrams of logic functions employed in the load-frequency system of the present invention;

60

Figures 6 and 7, respectively, show a base load limit curve and a flow chart used in the computation of a high load blocking limit; and

Figure 8 shows a basic flow chart for an LFC program used in the system.

65

More particularly, there is shown in Figure 1 a

power generation system 10 having a plurality of gas turbine-generator units 12 located at one or more plants within the area supplied by the system 10. Steam turbine-generator units are not shown, but a number of such units are provided in the system 10 to meet base load requirements. Each gas turbine-generator unit 12 is provided with a conventional control system 14, in this case a digital computer control system.

70

A central supervisory control 16 includes a load/frequency control 17 and provides tie-line interchange control and other control functions for the system 10. The control 16 includes conventional telemetering equipment for sending load dispatch signals to respective remote local supervisory controls 18 associated with the respective gas turbine-generator units 12. Plant signals including megawatts and megavar signals are transmitted back to the central control 16 from the local controls 18 for load dispatch calculations and other purposes.

85

A more detailed block diagram is shown for the local control arrangement in Figure 2. The control system 14 can be a conventional gas turbine computer control like that disclosed in U.S. Patent Application Serial No. 319,114, entitled 'Improved System And Method For Operating Industrial Gas Turbine Apparatus and Gas Turbine Electric Power Plants Preferably With A Digital Computer Control System', filed by T. Giras et al. on December 29, 1972.

95

Basically, the computer control 14 responds to temperature, pressure, fuel and other plant feedback signals and to operator and central supervisory signals to control the turbine fuel and thereby the turbine speed and/or load. As shown, RAISE or LOWER pulses are applied to a contact closure input system 21 by the local supervisory control 18 when the central supervisory control 16 has dispatched an increase or decrease in the local turbine load in order to control system frequency as the system electrical load and/or power interchange with neighboring systems varies.

100

105

A megawatt control 20, disclosed in the aforementioned Serial No. 319, 114, causes a fuel control 22 to change the fuel flow to a level which satisfies the megawatt load level setpoint as it is changed by incoming supervisory increase or decrease pulses. Normally, each supervisory pulse represents a demand for a load change equal to a predetermined number of megawatts.

110

115

To provide faster, more efficient and generally better system frequency control, the system 10 determines how much load each gas turbine-generator unit 12 can provide on the basis of its current operating condition. The system thus dynamically determines allowable loading on each turbine 12 in accordance with the physical health of the turbine and in accordance with ambient variables. Thus, as ambient conditions vary, and as gas turbine combustion efficiency, turbine blade performance, compressor fouling and other turbine health variables change with time, a high blocking limit, i.e., the turbine load capability, is continuously redetermined as a function of compressor discharge pressure and turbine-exhaust temperature and transmitted to the central supervisory control 16 where load com-

130

mands are calculated and dispatched to the gas turbine-generator units 12 on the basis of the respective high blocking limits. The respective gas turbines 12 move under local megawatt control th the dispatched load levels which are either at or below the respective high blocking limits, thereby normally achieving load/frequency control quickly on a feed-forward basis without incurring local trim action by exhaust temperature limit control. Thus, the use of the calculated high blocking limit for each turbine 12 in the dispatch calculations assures that the dispatched load for each gas turbine 12 will not exceed its high blocking limit, and further that each turbine 12 will not exceed its exhaust temperature limit when it is dispatched to move to a higher load no greater than its high blocking limit. With the use of the gas turbines 12 for frequency control, better system response and efficiency are realized as compared to the use of steam turbines for frequency control.

As an example, a gas turbine-generator unit may normally be capable of generating 100 MW at 80°F or 80 MW at 105°F. Once the turbine has been in use for some time, its physical state may be such that at 105°F it can only generate no more than 65 MW without exceeding exhaust temperature limits. With the control system disclosed herein, the reduced turbine operating capability is reflected as a dynamically calculated and reduced high load blocking limit which prevents the dispatch of over-limit load increases that cannot be met by that turbine.

An additional feature of the system is that it can include a turbine health monitor, i.e., a display which compares the current high blocking limit (HBL) to the rated or normal high blocking limit at the current ambient conditions. For this purpose, the local computer can keep in storage a curve representing the HBL values for the turbine at the start of life, i.e., HBL as a function of turbine exhaust temperature. In the alternative, the curve can be HBL as a linear function of compressor inlet temperature (see infra) as of the start of turbine life. The computer generates outputs corresponding to the actual and the stored HBL value for display.

To place an individual gas turbine-generator 12 in the load/frequency control mode, the operator pushes an Automatic Dispatch push button, and computer control logic operations are initiated as shown in Figure 3. If the turbine had been in temperature control, it is switched to megawatt control (Mode 3) and the load reference is set to a preset level below the high blocking limit to allow some range for frequency regulation. A block is placed on certain operations such as base mode, peak system reserve mode, manual load raise or lower, etc. as shown in Figure 3. As shown in Figure 4, computer logic operations allow acceptance of dispatch raise or lower pulses, and Figure 5 shows the logic employed in the computer to process raise or lower dispatch pulses as received. Each pulse signifies a fixed megawatt change and the load reference for the megawatt control is adjusted accordingly.

In the prior art, a static high blocking limit has been determined from compressor inlet temperature. Thus, the prior art high blocking limit is based

on the decrease in rated megawatts as the compressor inlet temperature increases. This temperature (T_1) is measured and the high blocking limit is generated as a linear function of T_1 . Since it is a static calculation, the line must be adjusted from time to time to take into account factors like turbine aging, change of fuel and, to a lesser extent, change in barometric pressure.

In accordance with a preferred embodiment of the present invention, a high blocking limit is calculated dynamically to provide better system efficiency. Thus, as fuel is increased, combustor shell pressure and exhaust temperature increase in approximately a linear fashion. So that the design value for turbine inlet temperature is not exceeded, the maximum allowable exhaust temperature is defined by a loading curve as a function of combustion shell pressure. The loading curve is approximated as four straight line segments as shown in Figure 6. Curves allowing higher turbine inlet temperatures at a cost of higher maintenance costs are available but only the lowest or base load curve is shown.

In Figure 6, there is shown a plot of the base load curve and a loading line, the locus of points plotting exhaust temperature (T_2) vs combustor shell pressure (P_2) as fuel is varied. The point where the two intersect (P_1, T_1) is the point where base load is reached and temperature control limits further increase. If other ambient temperatures and/or other turbine efficiency conditions exist, a different but essentially parallel loading path through (P_2, T_2) is followed (dotted line) giving a different intersection. The slope of the loading line is characteristic to the turbine and is empirically determined. Since there is good correlation between change in exhaust temperature and change in megawatts, calculating the temperature at the intersection gives the maximum allowable increase in exhaust temperature. The available increase in megawatts can be predicted from the present megawatts, the combustor shell pressure and the exhaust temperature and the maximum allowable exhaust temperature increase.


The present megawatts plus the available increase in megawatts becomes the high blocking limit which is telemetered to the central load dispatch system. Figure 7 shows a flow chart for the described basic logic operations performed in calculating HBL.

From knowledge of the present operating conditions P_A , T_A and W_A (megawatts), the intersection temperature can be shown to be calculated as $T_1 = d + T_A + e P_A + f$ where d , e , and f are constants. Since different constants are needed for each loading curve segment, there are four sets of constants d_n , e_n , f_n where $n = 1, 2, 3$ and 4. A calculation is made for the one set of constants and if T_1 does not fall in the first segment, calculations are made for succeeding segments until the actual intersection on the segment matching the constants is found. From there, the high blocking limit is calculated as $HBL = W_A + C(T_1 - T_A)$ where C is a constant.

Calculations update the HBL at regular intervals anytime the unit is above a predetermined load level such as minimum load. The low blocking limit can be calculated locally or remotely for narrow band limiting as either $LBL = a$, or $LBL = HBL - a_2$ or $LBL =$

$N_2(\text{HBL})$ where a_1, a_2 are constants. For wide band limiting, LBL can be made equal to the minimum load value specified for the turbine.

The following calculations are used to determine constants needed to predict allowable increase in exhaust temperature, hence megawatts.



at intersection, (P_1, T_1)

$$mP_1 + b = T_A + m_A(P_1 - P_A) = T_A + m_AP_1 - m_AP_A$$

$$mP_1 - m_AP_1 = T_A - m_AP_A - b$$

$$P_1(m - m_A) = T_A - m_AP_A - b$$

$$P_1 = \frac{T_A - m_AP_A - b}{(m - m_A)}$$

$$T_1 = mP_1 + b$$

$$T_1 = \frac{m}{m - m_A} (T_A - m_AP_A - b) + b$$

$$= \frac{m}{m - m_A} (T_A - m_AP_A) - \frac{mb}{m - m_A} + b$$

$$= \frac{m}{m - m_A} (T_A - m_AP_A) + \frac{-m_A b}{m - m_A}$$

$$= \frac{m}{m - m_A} (T_A - m_AP_A) - \frac{m_A b}{m - m_A}$$

$$T_1 = \frac{m}{m - m_A} T_A - \frac{mm_A}{m - m_A} P_A - \frac{m_A b}{m - m_A}$$

$$= dT_A + eP_A + f$$

At the dispatch computer 16, the LFC program computes load changes needed for frequency control and schedules load changes for individual units 12 to satisfy the total load change requirement within the constraints of the HBL values received from the various units 12. In Figure 8 a general block diagram is shown for an LFC sub-system.

AREA CONTROL ERROR (ACE)

The Area Control Error (ACE) program calculates the control error which the AGC system must minimize. To provide better control action, a controller algorithm is used on the ACE value to provide a smoothed, predicted, and compensated ACE. This value is used by the LFC program to regulate the generating units.

The area control error is the change in generation necessary to meet scheduled frequency and scheduled net interchange. The sign convention is as

follows:

Positive = Excess generation, power flow out of area.

Negative = Deficiency in generation, power flow into area.

The equation is:

$$E_A = P_T(1) - P_s + B(F - F_s)$$

where:

$P_T(1)$ = Flow on tie 1

P_s = Net Scheduled Interchange

B = Frequency Bias

F = System Frequency

F_s = Scheduled Frequency

Provision is made for considering different modes of control in the calculation.

LOAD FREQUENCY CONTROL PROGRAM

The purpose of the Load Frequency Control (LFC) Program is to calculate and assign megawatt output required from each generating unit to satisfy operating area control needs. The program uses several input values describing the current power requirement and the status of the generating units, and then determines each unit's assigned power. The power assignment is calculated according to the unit's economic point as decided by the Economic Dispatch Control (EDC) Program or the operator.

The power difference between the economic operating point and the total required power for the area is calculated. This power deviation is distributed to the various units according to a unit participation factor and the dynamic limits of the individual units. Each unit's economic operating point is then adjusted to absorb the power deviation to satisfy the total power requirement. However, if the sum of the participation factors is not 100 percent, or one or more units have exceeded the unit's allowable dynamic limits (as calculated in accordance with the present invention), the total power generation requirement may not be satisfied in the first assignment pass. In such cases, the LFC program adjusts the total power deviation and attempts to redistribute the power deviation to those units which can still handle it. Several iterations may be required, terminating when the difference between the generated and the required power is less than some acceptable error. Should the program fail to achieve total power within a fixed number of iterations, a nonconvergence alarm is initiated.

The program also checks the changes in certain system parameters over prescribed time intervals. If these changes become excessive, a new Economic Dispatch calculation will be made. This will also apply if a unit is added to or deleted from those being direct digitally controlled.

The basic function of the LFC can be stated as follows:

Power to be assigned = the sum of actual power of all BASE or AUTO minus smoothed and predicted area control error.

Regulating Power = power to be assigned minus the base settings of units on BASE or AUTO.

ECONOMIC DISPATCH CALCULATION PROGRAM

The function of the Economic Dispatch Control (EDC) Program is to calculate the economic loading

point for the various generating units. The results of this calculation are used by the Load Frequency Control (LFC) Program to regulate the power assignment based on the economic loading points to satisfy the area requirement. The results of the Pass II calculation are used by the operator to manually control the generating units in the fixed load mode.

To save running time, the program consists of two separate routines. The first calculates the incremental cost curve anytime pertinent parameter changes. Incremental heat rate curves are stored on RAD in the form of line segments (slope-intersect). This routine is run anytime the fuel cost has changed, or a heat rate curve has been modified. The fuel costs are modified via the dispatch console.

The second routine is the normal EDC economic loading calculation. A trial value of Lambda is assumed and each cost curve is entered to obtain the designed power. If the sum of the assigned power equals the required value within a specified boundary, the value of Lambda is correct and the solution is valid. If not, Lambda is increased or decreased and the numerical process is continued until the error criteria is satisfied. A binary search procedure is used to ensure rapid convergence and minimum running time. If the assigned power is outside the specified limits, it is set equal to that limit. If the required power cannot be reached within the limit calculated as described herein for the various units, an alarm message is output and no results are stored for the LFC program.

EDC is normally requested to execute at regular intervals. However, the program may also be requested by either the LFC Program or the operator. LFC bids indirectly for the EDC Program whenever the system operating point has drifted too far from the economic operating point. The operator may request EDC whenever the economic loading points of the generating units must be updated.

EDC calculates the economic loading points for each generating unit placed on AUTO control. The economic calculations are based on the principles of Incremental Loading, to achieve minimum overall fuel costs for a given System demand. The calculations recognize the most limiting unit constraints, unit fuel costs, and transmission loss penalty factors.

EDC dispatches a total system load, determined by LFC, among the available units. The program runs as requested on the basis of time, and/or megawatts change, and/or a flag due to an operator request. The desired power is obtained from LFC and the results, the desired power for each unit, are stored for LFC for consolidation.

TURBINE CONTROL PROGRAM AND PULSE TO

SUPY ROUTINE

The function of the Turbine Control Program is to compute unit error and the required control action in terms of raise or lower pulse rates. Turbine control action is computed every four seconds, but the response to a pulse rate by a typical turbine extends over several four second periods. It is therefore necessary to prevent the over-correction which would result if pulsing were based only on instantaneous error. The possibility of using faster pulse rates is ruled out. They are detrimental to the speed

of response and, thus, to regulation of the power system; and they also cause excessive thermal cycling in the gas turbine.

In the use of the mode feedback (anticipation), a simple model of the turbine is employed to anticipate changes in generation. The model used is a simple exponential decay, such that if correctly adjusted, the sum of actual plus anticipated power is constant.

The equations used in the program are:

$$\begin{aligned}\text{ANTIC}(N) &= \text{ANTIC}(N-1) * \text{DECAY} \\ \text{ERROR} &= \text{DESP} - (\text{ACTP} + \text{ANTIC}(N)) \\ \text{ANTIC}(N) &= \text{ANTIC}(N) + \text{ERROR} \\ \text{PULSE} &= \text{ERROR} * \text{CONV}\end{aligned}$$

where:

$$\begin{aligned}\text{DESP} &= \text{Desired Power (Setpoint from (LFC))} \\ \text{ACTP} &= \text{Actual Power (Feedback from REDAC 70 data point)} \\ \text{ANTIC} &= \text{Anticipated Change in Actual Power from previous pulse(s)} \\ \text{DECAY} &= \text{Exponential Decay in 4 sec.} \\ \text{CONV} &= \text{Pulses/MW} \\ \text{PULSE} &= \text{Output Pulse Rate}\end{aligned}$$

ANTIC is the anticipation term and represents the effect on the unit still to be produced by the previous pulses.

The first equation above shows how much ANTIC should have changed in the 4 sec. since the last pulse rate due to the response of the unit over time. The third equation above gives the total movement of the unit (occurring over a few control cycles) due to the pulse rate output previously and the pulse rate now about to be output.

For the model feedback rate to be effective, it is important that the CONV term represent an accurate conversion of pulse rate to megawatt error and that the DECAY term correspond to the actual dynamics of the turbine. While these terms are not constant over the entire range of turbine output, sufficient accuracy can be obtained by using a DECAY which is average over typical operating range, and CONV at the most responsive region.

The sustained rate of change of a controlled unit is limited by the Turbine Control program. The predetermined maximum sustained (thermal recovery) rate is stored for each unit as RATE in MW per 4 seconds. The rate limiting is mechanized by modeling the available step change of the gas turbines. When a pulse is sent out, the program considers that the available step has been reduced and that it will return to normal at the sustained rate of change described above. Although this use of available step as a physical entry applies only to increase in turbine output, it is used mathematically to limit changes in either direction.

In the computation of pulses, the available step (QADN, QAUP) is taken out as follows:

$$\begin{aligned}\text{MAX RAISE PULSE} &= \text{QAUP (Positive)} \\ \text{MAX LOWER PULSE} &= \text{QADN (Negative)}\end{aligned}$$

The magnitudes of QAUP and QADN build up to QMAX so that when no available step has been used, a step of QMAX (in MW) can be made in either direction. QMAX, then, is the maximum instantaneous

ous change capability of the turbine-generator combination. The available step is updated each control cycle, after the development of pulses and the calculation of anticipation.

5 CLAIMS

1. A load-frequency control system for a power system having a plurality of gas turbine-generator units, said control system comprising means for controlling the load level of each of said gas turbine-generator units to satisfy a load reference applied thereto, means for generating the load references for the respective units to provide for substantially constant system frequency substantially without exceeding a high blocking limit for each of said units, means provided for generating representation of turbine exhaust temperature and combustor shell pressure for each unit, and means for dynamically generating the high blocking limit for each of said units as a function of the turbine exhaust temperature and the combustor shell pressure.

2. A load-frequency control system as set forth in claim 1 wherein a low blocking limit is also generated for each gas turbine-generator unit for implementation through said load reference generating means.

3. A load-frequency control system as set forth in claim 1 or 2 wherein a central load dispatch computer includes load-frequency control means for generating load increase-decrease signals for the gas turbine-generator units, each of said gas turbine-generator units includes a local control system including said load level controlling means and said high blocking limit generating means, and means are provided for transmitting signals representing the high blocking limits to said dispatch computer and the load increase-decrease signals to said local control systems.

4. A load-frequency control system as set forth in claim 1, 2 or 3 wherein health monitor display means are provided for comparing the dynamically determined high blocking limit with a stored expected value for the high blocking limit at the measured turbine exhaust temperature and existing ambient.

5. A load-frequency system as set forth in claim 1, 2, 3 or 4 wherein means are provided for generating a representation of actual megawatts for each unit, the high blocking limit is dynamically determined for each unit by adding measured megawatts to available increase in megawatts, and the available increase in megawatts is determined for each unit as the intersect of a stored characteristic temperature limit versus combustor shell pressure loading curve for the gas turbine and a loading line having a predetermined slope and extending from the measured exhaust temperature value through the characteristic temperature limit curve.

6. A load-frequency control system substantially as described hereinbefore with respect to, and as shown in, the accompanying drawings.